



THESE COLUMNS REPRESENT ALL OF THE AVAILABLE ALARMS. EACH YELLOW BOX WITH A "1" IN IT REPRESENTS AN INCIDENT WHERE THAT ALARM WAS TRIGGERED

	DATE & TIME	ALARM MASK	SYSTEM IN OVERRIDE	NO COOLANT FLOW	HIGH JACKET TEMPERATURE	JACKET TEMPERATURE WARNING	LOW COOLANT FLOW	HIGH COOLANT PRESSURE	GAP LIMIT REACHED	LOW FRESH WATER FLOW	HIGH FRESH WATER TEMPERATURE	RESTRICTED FRESH EXCHANGER	RESTRICTED FRESH STRAINER	RESTRICTED COOLANT EXCHANGER	SYSTEM STATE
40															
41	2/11/14 18:01	22	0	1	0	0	0	1	0	0	0	0	0	0	0 LOCKDOWN
42	2/11/14 18:01	2	0	1	0	0	0	0	0	0	0	0	0	0	0 LOCKDOWN
43	2/11/14 18:01	10	0	0	0	0	1	0	0	0	0	0	0	0	0 DANGER
44	2/11/14 18:01	0	0	0	0	0	0	0	0	0	0	0	0	0	0 NORMAL
45	2/11/14 18:02	80	0	0	0	0	0	0	0	1	0	0	0	0	0 WARNING
46	2/11/14 18:02	480	0	0	0	0	0	0	0	1	0	0	1	0	0 WARNING
47	2/11/14 18:02	80	0	0	0	0	0	0	0	1	0	0	0	0	0 WARNING
48	2/11/14 18:03	0	0	0	0	0	0	0	0	0	0	0	0	0	0 NORMAL
49	2/11/14 18:03	80	0	0	0	0	0	0	0	1	0	0	0	0	0 WARNING
50	2/11/14 18:03	280	0	0	0	0	0	0	0	1	0	1	0	0	0 WARNING
51	2/11/14 18:03	80	0	0	0	0	0	0	0	1	0	0	0	0	0 WARNING
52	2/11/14 18:03	0	0	0	0	0	0	0	0	0	0	0	0	0	0 NORMAL
53	2/12/14 9:01	0	0	0	0	0	0	0	0	0	0	0	0	0	0 NORMAL
54	2/12/14 9:08	0	0	0	0	0	0	0	0	0	0	0	0	0	0 NORMAL
55	2/12/14 9:08	80	0	0	0	0	0	0	0	1	0	0	0	0	0 WARNING
56	2/12/14 9:08	0	0	0	0	0	0	0	0	0	0	0	0	0	0 NORMAL
57	2/12/14 10:02	100	0	0	0	0	0	0	0	0	1	0	0	0	0 WARNING

THESE COLUMNS RECORD THE SENSOR READINGS AT THE INSTANT EACH ALARM WAS TRIGGERED

LINE (REF)	DATE & TIME	P8-Cin 2 Brake Apply Press	G1-Gross Brake Apply Stroke	P7-Cin 1 Brake Apply Press	RPM-Drum	P5-Coolant Outlet Pressure-Brake	T6-Coolant Outlet Temp-Brake	P6-Coolant Flow Pressure	T5-Coolant Inlet Temp-Brake	T4-Coolant Inlet Temp-Exchanger	T3-Fresh Water Outlet Temp-Exchanger	P4-Coolant Inlet Pressure-Exchanger	P3-Fresh Water Flow Pressure	T2-Fresh Water Inlet Temp-Exchanger	F1-Spare	P2-Fresh Water Inlet Pressure-Exchanger	P1-Fresh Strainer Inlet Press
1	2/11/14 17:47	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
2	2/11/14 17:48	0	140	0	1.4	0	90	0	90	90	89	30	12	90	0	5.6	17
3	2/11/14 17:48	0	140	0	1.4	2.6	90	3.8	90	90	89	22	12	90	0	5.8	17
4	2/11/14 17:48	0	140	0	1.4	5	90	7.7	90	90	89	20	12	90	0	5.6	17
5	2/11/14 17:48	0	140	0	1.4	0.1	90	0	91	91	90	26	12	91	0	5.8	17
6	2/11/14 17:48	0	140	0	1.4	0.1	90	0	91	91	90	27	12	91	0	5.8	17
7	2/11/14 17:48	0	140	0	1.4	3.1	90	4.1	91	91	90	23	12	91	0	5.8	17
8	2/11/14 17:48	0	140	0	1.4	4	90	5.5	91	91	90	21	12	91	0	5.8	17
9	2/11/14 17:49	0	140	0	1.4	0	90	0	91	91	90	30	12	91	0	5.6	17
10	2/11/14 17:49	0	140	0	1.4	0	90	0	91	91	90	30	12	91	0	5.6	17
11	2/11/14 17:49	0	140	0	1.4	2.9	90	4.1	91	92	91	21	12	92	0	5.6	17
12	2/11/14 17:49	0	140	0	1.4	5.1	90	7.7	92	92	91	20	12	92	0	5.6	17
13	2/11/14 17:52	0	140	0	2.2	0	95	0	95	95	94	29	12	95	0	5.5	17
14	2/11/14 17:53	0	140	0	2.2	4	95	5.4	95	95	95	21	12	95	0	5.5	17
15	2/11/14 17:53	0	140	0	2.2	5.2	95	7.4	95	95	95	20	12	95	0	5.5	17
16	2/11/14 17:53	0	140	0	2.2	0	95	0	95	96	95	28	12	96	0	5.5	17
17	2/11/14 17:53	0	140	0	2.2	0	95	0	95	96	95	28	12	96	0	5.5	17
18	2/11/14 17:53	0	140	0	2.2	4.5	95	6.3	96	96	95	20	12	96	0	5.5	17
19	2/11/14 17:53	0	140	0	2.2	0	95	0	96	96	96	33	12	96	0	5.5	17
20	2/11/14 17:53	0	140	0	2.2	0	95	0	96	96	96	33	12	97	0	5.5	17
21	2/11/14 17:53	0	140	0	2.2	4	95	5.5	96	96	96	22	12	97	0	5.5	17
22	2/11/14 17:56	0	829	45	1.4	5.2	98	7.5	99	99	98	19	12	99	0	5.5	17
23	2/11/14 17:56	0	142	0	1.4	5.2	98	7.5	99	99	98	19	12	99	0	5.5	17
24	2/11/14 17:56	0	829	23	1.4	5.2	98	7.5	99	99	98	19	12	99	0	5.5	17
25	2/11/14 17:56	0	140	0	469	5.2	98	7.5	99	99	98	19	12	99	0	5.5	17
26	2/11/14 17:58	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
27	2/11/14 17:58	0	140	0	2.3	5	100	7.5	101	101	100	15	6.7	101	0	3	13
28	2/11/14 17:58	0	940	39	2.3	5	100	7.5	101	101	100	19	12	101	0	5.5	17
29	2/11/14 17:59	0 ***		50	2.3	5.2	100	7.5	101	101	100	19	12	101	0	5.5	17
30	2/11/14 17:59	0	140	0	2.3	5.2	100	7.5	101	101	101	19	12	101	0	5.5	17
31	2/11/14 18:00	0	140	0	2.3	2.8	101	3.4	102	102	101	22	12	102	0	5.5	17
32	2/11/14 18:00	0	140	0	2.3	2.6	101	3.4	102	102	101	22	12	102	0	5.5	17
33	2/11/14 18:00	0	140	0	2.3	1.5	101	1.4	102	102	101	24	12	102	0	5.5	17
34	2/11/14 18:00	0	140	0	2.3	2.3	101	3	102	102	101	22	12	102	0	5.5	17
35	2/11/14 18:00	0	140	0	2.3	3.7	101	5.2	102	102	101	21	12	102	0	5.5	17
36	2/11/14 18:00	0	140	0	2.3	10	101	12	102	102	102	21	12	102	0	5.5	17
37	2/11/14 18:01	0	140	0	2.3	14	102	14	103	103	102	23	12	102	0	5.5	17
38	2/11/14 18:01	0	140	0	2.3	33	102	29	103	103	102	33	12	103	0	5.5	17
39	2/11/14 18:01	0	140	0	2.3	33	102	29	103	103	102	32	12	103	0	5.5	17

THESE COLUMNS RECORD THE SENSOR READINGS AT THE INSTANT THE ALARM WAS TRIGGERED

	DATE & TIME	P8-Chn 2 Brake Apply Press	G1-Gross Brake Apply Stroke	P7-Chn 1 Brake Apply Press	RPM-Drum	P5-Coolant Outlet Pressure-Brake	T6-Coolant Outlet Temp-Brake	P6-Coolant Flow Pressure	T5-Coolant Inlet Temp-Brake	T4-Coolant Inlet Temp-Exchanger	T3-Fresh Water Outlet Temp-Exchanger	P4-Coolant Inlet Pressure-Exchanger	P3-Fresh Water Flow Pressure	T2-Fresh Water Inlet Temp-Exchanger	F1-Spare	P2-Fresh Water Inlet Pressure-Exchanger	P1-Fresh Strainer Inlet Press
40																	
41	2/11/14 18:01	0	140	0	2.3	33	102	29	103	103	102	32	12	103	0	5.5	17
42	2/11/14 18:01	0	140	0	2.3	23	101	22	102	103	103	26	12	103	0	5.5	17
43	2/11/14 18:01	0	140	0	2.3	14	101	15	102	103	103	24	12	103	0	5.5	17
44	2/11/14 18:01	0	140	0	2.3	9.6	101	11	102	103	103	19	12	103	0	5.7	17
45	2/11/14 18:02	0	140	0	2.3	5.1	103	7.3	104	103	103	19	6.7	104	0	3	20
46	2/11/14 18:02	0	140	0	2.3	4.9	103	7.3	104	103	103	19	3.3	104	0	1.3	22
47	2/11/14 18:02	0	140	0	2.3	5	104	7.3	104	104	104	19	4.4	105	0	1.8	21
48	2/11/14 18:03	0	140	0	2.3	5	104	7.3	104	104	104	19	8.6	105	0	4	19
49	2/11/14 18:03	0	140	0	2.3	4.8	104	7.3	104	104	104	19	15	105	0	13	20
50	2/11/14 18:03	0	140	0	2.3	5	104	7.3	104	104	104	19	16	105	0	14	20
51	2/11/14 18:03	0	140	0	2.3	5.1	104	7.3	104	104	104	19	16	105	0	13	20
52	2/11/14 18:03	0	140	0	2.3	4.9	104	7.3	105	104	104	19	14	105	0	9.2	19
53	2/12/14 9:01	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
54	2/12/14 9:08	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
55	2/12/14 9:08	0	137	0	1.7	5.2	78	7.7	79	79	77	15	7	79	0	3.2	13
56	2/12/14 9:08	0	137	0	1.7	5.2	78	7.7	79	79	77	20	12	79	0	5.7	18
57	2/12/14 10:02	0	142	0	1.7	5.1	119	7.2	119	119	119	19	11	120	0	5.2	17

THESE COLUMNS RECORD ALL CALCULATED VALUES AT THE INSTANT EACH ALARM WAS TRIGGERED

THESE COLUMNS TRACK ALL SETPOINTS SO WE CAN SEE EXACTLY WHEN ANY ARE CHANGED

LINE (REF)	DATE & TIME	BLOCK SPEED ft./min	BRAKE APPLICATION (hp)	STRAINER %	NET GAP	COOLANT FLOW %	FRESH WATER FLOW %	COMMENTS	SP-NO COOLANT FLOW	SP-HIGH JACKET TEMPERATURE	SP-JACKET TEMPERATURE WARNING	SP-LOW COOLANT FLOW	SP-HIGH COOLANT PRESSURE	SP-GAP LIMIT REACHED	SP-LOW FRESH WATER FLOW	SP-HIGH FRESH WATER TEMPERATURE	SP-RESTRICTED FRESH EXCHANGER	SP-RESTRICTED FRESH STRAINER	SP-RESTRICTED COOLANT EXCHANGER
1	2/11/14 17:47	0	0	0	0	0	0	System Started	50	170	155	80	30	680	80	120	230	19	130
2	2/11/14 17:48	1	0	98	-1	0	99		50	170	155	80	30	680	80	120	230	19	130
3	2/11/14 17:48	1	0	99	-1	72	97		50	170	155	80	30	680	80	120	230	19	130
4	2/11/14 17:48	1	0	98	-1	109	99		50	170	155	80	30	680	80	120	230	19	130
5	2/11/14 17:48	1	0	98	-1	0	97		50	170	155	80	30	680	80	120	230	19	130
6	2/11/14 17:48	1	0	98	-1	0	97		50	170	155	80	30	680	80	120	230	19	130
7	2/11/14 17:48	1	0	100	-1	64	97		50	170	155	80	30	680	80	120	230	19	130
8	2/11/14 17:48	1	0	100	-1	81	97		50	170	155	80	30	680	80	120	230	19	130
9	2/11/14 17:49	1	0	98	-1	0	99		50	170	155	80	30	680	80	120	230	19	130
10	2/11/14 17:49	1	0	98	-1	0	99		50	170	155	80	30	680	80	120	230	19	130
11	2/11/14 17:49	1	0	98	-1	72	99		50	170	155	80	30	680	80	120	230	19	130
12	2/11/14 17:49	1	0	98	-1	107	99		50	170	155	80	30	680	80	120	230	19	130
13	2/11/14 17:52	1	0	99	-1	0	96		50	170	155	80	30	680	80	120	230	19	130
14	2/11/14 17:53	1	0	99	-1	79	96		50	170	155	80	30	680	80	120	230	19	130
15	2/11/14 17:53	1	0	99	-1	99	96		50	170	155	80	30	680	80	120	230	19	130
16	2/11/14 17:53	1	0	99	-1	0	96		50	170	155	80	30	680	80	120	230	19	130
17	2/11/14 17:53	1	0	99	-1	0	96		50	170	155	80	30	680	80	120	230	19	130
18	2/11/14 17:53	1	0	99	-1	89	96		50	170	155	80	30	680	80	120	230	19	130
19	2/11/14 17:53	1	0	99	-1	0	96		50	170	155	80	30	680	80	120	230	19	130
20	2/11/14 17:53	1	0	99	-1	0	96		50	170	155	80	30	680	80	120	230	19	130
21	2/11/14 17:53	1	0	99	-1	82	96		50	170	155	80	30	680	80	120	230	19	130
22	2/11/14 17:56	1	10	97	688	100	96		50	170	155	80	30	680	80	120	230	19	130
23	2/11/14 17:56	1	0	99	2	100	96		50	170	155	80	30	680	80	120	230	19	130
24	2/11/14 17:56	1	5	99	688	100	96		50	170	155	80	30	680	80	120	230	19	130
25	2/11/14 17:56	393	0	99	0	99	96		50	170	155	80	30	680	80	120	230	19	130
26	2/11/14 17:58	0	0	0	0	0	0	System Started	50	170	155	80	30	680	80	120	230	19	130
27	2/11/14 17:58	1	0	100	0	104	74		50	170	155	80	30	680	80	120	230	19	130
28	2/11/14 17:58	1	15	99	800	104	96		50	170	155	80	30	680	80	120	230	19	130
29	2/11/14 17:59	1	19	99	861	100	96		50	170	155	80	30	680	80	120	230	19	130
30	2/11/14 17:59	1	0	99	0	100	96		50	170	155	80	30	680	80	120	230	19	130
31	2/11/14 18:00	1	0	98	0	51	96		50	170	155	80	30	680	80	120	230	19	130
32	2/11/14 18:00	1	0	98	0	60	96		50	170	155	80	30	680	80	120	230	19	130
33	2/11/14 18:00	1	0	100	0	0	96		50	170	155	80	30	680	80	120	230	19	130
34	2/11/14 18:00	1	0	100	0	53	96		50	170	155	80	30	680	80	120	230	19	130
35	2/11/14 18:00	1	0	100	0	81	96		50	170	155	80	30	680	80	120	230	19	130
36	2/11/14 18:00	1	0	100	0	69	96		50	170	155	80	30	680	80	120	230	19	130
37	2/11/14 18:01	1	0	100	0	0	96		50	170	155	80	30	680	80	120	230	19	130
38	2/11/14 18:01	1	0	100	0	0	96		50	170	155	80	30	680	80	120	230	19	130
39	2/11/14 18:01	1	0	100	0	0	96		50	170	155	80	30	680	80	120	230	19	130

THESE COLUMNS RECORD ALL CALCULATED VALUES AT THE INSTANT ANY ALARM WAS TRIGGERED

THESE COLUMNS TRACK ALL SETPOINTS SO WE CAN SEE EXACTLY WHEN ANY ARE CHANGED

	DATE & TIME	BLOCK SPEED ft/min	BRAKE APPLICATION (hp)	STRAINER %	NET GAP	COOLANT FLOW %	FRESH WATER FLOW %	COMMENTS	SP-NO COOLANT FLOW	SP-HIGH JACKET TEMPERATURE	SP-JACKET TEMPERATURE WARNING	SP-LOW COOLANT FLOW	SP-HIGH COOLANT PRESSURE	SP-GAP LIMIT REACHED	SP-LOW FRESH WATER FLOW	SP-HIGH FRESH WATER TEMPERATURE	SP-RESTRICTED FRESH EXCHANGER	SP-RESTRICTED FRESH STRAINER	SP-RESTRICTED COOLANT EXCHANGER
40																			
41	2/11/14 18:01	1	0	100	0	0	96		50	170	155	80	30	680	80	120	230	19	130
42	2/11/14 18:01	1	0	98	0	0	96		50	170	155	80	30	680	80	120	230	19	130
43	2/11/14 18:01	1	0	98	0	56	96		50	170	155	80	30	680	80	120	230	19	130
44	2/11/14 18:01	1	0	99	0	83	95		50	170	155	80	30	680	80	120	230	19	130
45	2/11/14 18:02	1	0	69	0	99	74		50	170	155	80	30	680	80	120	230	19	130
46	2/11/14 18:02	1	0	56	0	103	55		50	170	155	80	30	680	80	120	230	19	130
47	2/11/14 18:02	1	0	60	0	100	63		50	170	155	80	30	680	80	120	230	19	130
48	2/11/14 18:03	1	0	78	0	100	83		50	170	155	80	30	680	80	120	230	19	130
49	2/11/14 18:03	1	0	100	0	104	65		50	170	155	80	30	680	80	120	230	19	130
50	2/11/14 18:03	1	0	100	0	100	57		50	170	155	80	30	680	80	120	230	19	130
51	2/11/14 18:03	1	0	100	0	99	63		50	170	155	80	30	680	80	120	230	19	130
52	2/11/14 18:03	1	0	100	0	103	81		50	170	155	80	30	680	80	120	230	19	130
53	2/12/14 9:01	0	0	0	0	0	0	System Started	50	170	155	80	30	680	80	120	230	19	130
54	2/12/14 9:08	0	0	0	0	0	0	System Started	50	170	155	80	30	680	80	120	230	19	130
55	2/12/14 9:08	1	0	100	-3	105	76		50	170	155	80	30	680	80	120	230	19	130
56	2/12/14 9:08	1	0	96	-3	105	98		50	170	155	80	30	680	80	120	230	19	130
57	2/12/14 10:02	1	0	100	2	94	96		50	170	155	80	30	680	80	120	230	19	130

THESE COLUMNS TRACK ALL LEARNED VALUES AND ALARM ENABLES (1=ON) SO WE CAN SEE EXACTLY WHEN ANY ARE CHANGED

LINE (REF)	DATE & TIME	G1- Learned Value	P5- Learned Value	P6- Learned Value	P4- Learned Value	P3- Learned Value	P2- Learned Value	P1- Learned Value	ENABLE LIGHT	ENABLE HORN	ENABLE LOCKDOWN	OVER HP ALARM
1	2/11/14 17:47	142	5.2	7.5	20	13	5.8	17	1	1	1	1
2	2/11/14 17:48	142	5.2	7.5	20	13	5.8	17	0	1	1	1
3	2/11/14 17:48	142	5.2	7.5	20	13	5.8	17	0	1	1	1
4	2/11/14 17:48	142	5.2	7.5	20	13	5.8	17	0	1	1	1
5	2/11/14 17:48	142	5.2	7.5	20	13	5.8	17	0	0	1	1
6	2/11/14 17:48	142	5.2	7.5	20	13	5.8	17	0	0	1	1
7	2/11/14 17:48	142	5.2	7.5	20	13	5.8	17	0	0	1	1
8	2/11/14 17:48	142	5.2	7.5	20	13	5.8	17	0	0	1	1
9	2/11/14 17:49	142	5.2	7.5	20	13	5.8	17	0	0	0	1
10	2/11/14 17:49	142	5.2	7.5	20	13	5.8	17	0	0	0	1
11	2/11/14 17:49	142	5.2	7.5	20	13	5.8	17	0	0	0	1
12	2/11/14 17:49	142	5.2	7.5	20	13	5.8	17	0	0	0	1
13	2/11/14 17:52	142	5.2	7.5	20	13	5.8	17	1	0	0	1
14	2/11/14 17:53	142	5.2	7.5	20	13	5.8	17	1	0	0	1
15	2/11/14 17:53	142	5.2	7.5	20	13	5.8	17	1	0	0	1
16	2/11/14 17:53	142	5.2	7.5	20	13	5.8	17	1	1	0	1
17	2/11/14 17:53	142	5.2	7.5	20	13	5.8	17	1	1	0	1
18	2/11/14 17:53	142	5.2	7.5	20	13	5.8	17	1	1	0	1
19	2/11/14 17:53	142	5.2	7.5	20	13	5.8	17	1	1	1	1
20	2/11/14 17:53	142	5.2	7.5	20	13	5.8	17	1	1	1	1
21	2/11/14 17:53	142	5.2	7.5	20	13	5.8	17	1	1	1	1
22	2/11/14 17:56	140	5.2	7.5	20	13	5.8	17	1	1	1	1
23	2/11/14 17:56	140	5.2	7.5	20	13	5.8	17	1	1	1	1
24	2/11/14 17:56	140	5.2	7.5	20	13	5.8	17	1	1	1	1
25	2/11/14 17:56	140	5.2	7.5	20	13	5.8	17	1	1	1	1
26	2/11/14 17:58	140	5.2	7.5	20	13	5.8	17	1	1	1	1
27	2/11/14 17:58	140	5.2	7.5	20	13	5.8	17	1	1	1	1
28	2/11/14 17:58	140	5.2	7.5	20	13	5.8	17	1	1	1	1
29	2/11/14 17:59	140	5.2	7.5	20	13	5.8	17	1	1	1	1
30	2/11/14 17:59	140	5.2	7.5	20	13	5.8	17	1	1	1	1
31	2/11/14 18:00	140	5.2	7.5	20	13	5.8	17	1	1	1	1
32	2/11/14 18:00	140	5.2	7.5	20	13	5.8	17	1	1	1	1
33	2/11/14 18:00	140	5.2	7.5	20	13	5.8	17	1	1	1	1
34	2/11/14 18:00	140	5.2	7.5	20	13	5.8	17	1	1	1	1
35	2/11/14 18:00	140	5.2	7.5	20	13	5.8	17	1	1	1	1
36	2/11/14 18:00	140	5.2	7.5	20	13	5.8	17	1	1	1	1
37	2/11/14 18:01	140	5.2	7.5	20	13	5.8	17	1	1	1	1
38	2/11/14 18:01	140	5.2	7.5	20	13	5.8	17	1	1	1	1
39	2/11/14 18:01	140	5.2	7.5	20	13	5.8	17	1	1	1	1

THESE COLUMNS TRACK ALL LEARNED VALUES AND ALARM ENABLES (1=ON) SO WE CAN SEE EXACTLY WHEN WHEN ANY ARE CHANGED

	DATE & TIME	G1- Learned Value	P5- Learned Value	P6- Learned Value	P4- Learned Value	P3- Learned Value	P2- Learned Value	P1- Learned Value	ENABLE LIGHT	ENABLE HORN	ENABLE LOCKDOWN	OVER HP ALARM
40												
41	2/11/14 18:01	140	5.2	7.5	20	13	5.8	17	1	1	1	1
42	2/11/14 18:01	140	5.2	7.5	20	13	5.8	17	1	1	1	1
43	2/11/14 18:01	140	5.2	7.5	20	13	5.8	17	1	1	1	1
44	2/11/14 18:01	140	5.2	7.5	20	13	5.8	17	1	1	1	1
45	2/11/14 18:02	140	5.2	7.5	20	13	5.8	17	1	1	1	1
46	2/11/14 18:02	140	5.2	7.5	20	13	5.8	17	1	1	1	1
47	2/11/14 18:02	140	5.2	7.5	20	13	5.8	17	1	1	1	1
48	2/11/14 18:03	140	5.2	7.5	20	13	5.8	17	1	1	1	1
49	2/11/14 18:03	140	5.2	7.5	20	13	5.8	17	1	1	1	1
50	2/11/14 18:03	140	5.2	7.5	20	13	5.8	17	1	1	1	1
51	2/11/14 18:03	140	5.2	7.5	20	13	5.8	17	1	1	1	1
52	2/11/14 18:03	140	5.2	7.5	20	13	5.8	17	1	1	1	1
53	2/12/14 9:01	140	5.2	7.5	20	13	5.8	17	1	1	1	1
54	2/12/14 9:08	140	5.2	7.5	20	13	5.8	17	1	1	1	1
55	2/12/14 9:08	140	5.2	7.5	20	13	5.8	17	1	1	1	1
56	2/12/14 9:08	140	5.2	7.5	20	13	5.8	17	1	1	1	1
57	2/12/14 10:02	140	5.2	7.5	20	13	5.8	17	1	1	1	1